

THIS ENDORSEMENT CHANGES THE POLICY. PLEASE READ IT CAREFULLY.

PROTECTIVE SAFEGUARDS

This endorsement modifies insurance provided under the following:

COMMERCIAL PROPERTY COVERAGE PART
STANDARD PROPERTY POLICY

SCHEDULE

Premises Number	Building Number	Protective Safeguards Symbols Applicable
Describe Any "P-9":		

A. The following is added to the Commercial Property Conditions:

Protective Safeguards

As a condition of this insurance, you are required to:

1. Maintain the protective safeguards listed in the Schedule, and over which you have control, in complete working order;
2. Actively engage and maintain in the "on" position at all times any automatic fire alarm or other automatic system listed in the Schedule; and
3. Notify us if you know of any suspension of or impairment in any protective safeguard listed in the Schedule.

However, if part of an Automatic Sprinkler System or Automatic Commercial Cooking Exhaust And Extinguishing System is shut off due to breakage, leakage, freezing conditions or opening of sprinkler heads, notification to us will not be necessary if you can restore full protection within 48 hours.

B. The following is added to the **Exclusions** section of:

- Causes Of Loss – Basic Form
- Causes Of Loss – Broad Form
- Causes Of Loss – Special Form
- Mortgageholders Errors And Omissions Coverage Form
- Standard Property Policy

We will not pay for loss or damage caused by or resulting from fire if, prior to the fire, you failed to comply with any condition set forth in Paragraph **A**.

C. The protective safeguards to which this endorsement applies are identified by the following symbols:

"P-1" Automatic Sprinkler System, including related supervisory services.

Automatic Sprinkler System means:

- a. Any automatic fire protective or extinguishing system, including connected:
 - (1) Sprinklers and discharge nozzles;
 - (2) Ducts, pipes, valves and fittings;
 - (3) Tanks, their component parts and supports; and
 - (4) Pumps and private fire protection mains.
- b. When supplied from an automatic fire protective system:
 - (1) Non-automatic fire protective systems; and
 - (2) Hydrants, standpipes and outlets.

"P-2" Automatic Fire Alarm, protecting the entire building, that is:

- a. Connected to a central station; or
- b. Reporting to a public or private fire alarm station.

"P-3" Security Service, with a recording system or watch clock, making hourly rounds covering the entire building, when the premises are not in actual operation.

"P-4" Service Contract with a privately owned fire department providing fire protection service to the described premises.

"P-5" Automatic Commercial Cooking Exhaust And Extinguishing System installed on cooking appliances and having the following components:

- a. Hood;
- b. Grease removal device;
- c. Duct system; and
- d. Wet chemical fire extinguishing equipment.

"P-9", the protective system described in the Schedule.